

**University Area Joint Authority** 

# **Spring Creek Pollution Control Facility**



**Odor Control Study** Part 2 - Alternatives Evaluation

PMAA 2016 Annual **Conference and Trade** Show: August 29, 2016

Presented by:

#### Benjamin R. Burns

Project Manager Herbert, Rowland & Grubic, Inc.



## **Basis for Alternative Development**


- 95% Odor Reduction at the Dewatering Facility and the Compost Facility would result in less than five (1-hour) off-site odor events (D/T > 7) in a five year period.
- Ventilation Rates (NFPA 820 and WEF Manual of Practice No. 8)
  - Dewatering Facility 24,000 cfm (12 AC/h in Building; 4 AC/h in tanks)
  - Compost Facility 131,000 cfm (12/h AC in Compost Bay Area)

# **Odor Control Technologies**

- Chemical Scrubber
- Photoionization
- Carbon Adsorber
- Bio-trickling Filter
- Liquid Sludge Treatment
- Ionization
- Biofiltration

## **Chemical Scrubber**

- Three Stage System for H<sub>2</sub>S and NH<sub>3</sub> removal.
- Absorption of H<sub>2</sub>S into alkaline liquid (NaOH)
- Oxidation of H<sub>2</sub>S in solution (NaOCl)
- Absorption of NH<sub>3</sub> into water
- Chemical reaction of NH<sub>3</sub> with sulfuric acid (H<sub>2</sub>SO<sub>4</sub>)
- Oxidation of organic odorants with NaOCI



## **Chemical Scrubber**

## **Advantages**

- Simple and stable operation
- 99.5% removal of H<sub>2</sub>S
- Adaptable to changes in pollutant loading
- Small footprint
- Relatively low profile
- Relatively low capital cost
- Not dependent on maintaining a biomass
- Periodic operation

## Disadvantages

- Storage and handling of NaOH, NaOCI, H<sub>2</sub>SO<sub>4</sub>
- Limited effectiveness on organicbased odorants
- Water consumption (would require softening if not Reclaimed Water)
- Blowdown to treatment plant
- Particulate Matter can cause media plugging
- Freeze concerns with exterior applications

## **Photoionization**

#### **Treatment Description**

- UV light and a catalyst breakdown odorants.
- UV light creates oxidizing agents (O<sup>-2</sup>, OH<sup>-</sup>, O<sub>3,</sub> activated O<sub>2</sub> and other free radicals)
- Untreated compounds are trapped in the catalyst and broken down.











Raw off-gas

NEUTRALOX Photoionisation

Cleaned air

## **Photoionization**

## **Advantages**

- >95% odor reduction
- Simple operation and maintenance
- Adaptable to changes in pollutant loading
- Small footprint
- Not dependent on maintaining a biomass
- No water or chemical usage
- Periodic operation
- Possibility of heat recovery
- Low back pressure (2 to 3 in WC)
- Wide temperature range (-30 °C to 70 °C)


## Disadvantages

- Limited installations in North America
- Relatively high capital cost
- Consumables (UV lights and catalyst)
- Ozone generation (captured by catalyst?)

## **Carbon Adsorption**

- Packed activated carbon vessels
- Adsorption physical adherence of molecules to surface of media
- Activated carbon has very high surface area





## **Carbon Adsorbers**

## **Advantages**

- Simple and stable operation
- >95% odor reduction
- Handles changes in pollutant loading
- Small footprint
- Not dependent on maintaining a biomass
- No water or chemical usage

## Disadvantages

- Higher pollutant loadings reduce bed life (higher frequency of media change out)
- Carbon bed replacement can be costly and labor intensive
- Spent carbon must be disposed of properly (landfill) for high capacity carbon
- Not effective at removal of ammonia
- Limited effectiveness at removal of amines

# **Bio-Trickling Filter**

- Natural metabolic actions of microorganisms degrade odorants
- Countercurrent flow of air and water through synthetic media



# **Bio-Trickling Filter**

## **Advantages**

- Minimal maintenance
- Synthetic media long life (10 years)
- Programmable irrigation and nutrient control
- No chemicals

## Disadvantages

- Requires water and sometimes nutrients
- Freeze concerns
- Must maintain biological activity
- Unable to handle odor spikes
- Difficult to maintain efficient removal of reduced sulfur organic compounds

# **Liquid Sludge Treatment**

## **Treatment Description**

 VX456 – Selective Oxidant with specificity to sulfides and related organic odorants



# **Liquid Sludge Treatment**

## **Advantages**

- Low capital cost
- Easy to pilot
- Controls odors in building space

## Disadvantages

- Controls odors for 24-72 hours; concern of odor release downstream
- Chemical usage substantially increased when treating storage tanks
- Chemical is highly corrosive
- Fire hazard when allowed to dry

## **Ionization**

- Ionization systems supply highly ionized air with O<sup>2+</sup> and O<sup>2-</sup> ions to the application areas
- lons form molecular ion clusters with high oxidizing power.





## Ionization

## **Advantages**

- Improves indoor air quality
- Interior dust control
- Interior corrosion control
- Ion generators sized for each discrete space
- Potential for heat recovery
- Ion Generator serves as make-up air
- Low pressure drop systems
- Low footprint and low profile


## Disadvantages

- Relatively high capital cost
- ~90% H<sub>2</sub>S and NH<sub>3</sub> reduction
- Consumables (ion tubes)
- Air distribution laterals in building space

## **Biofiltration**

- Natural metabolic actions of microorganisms degrade odorants
- Organic or mineral based media





## **Biofiltration**

#### **Advantages**

- Low operation and maintenance costs
- 90-95% odor reduction
- No chemical usage
- Relatively high static pressures (5 9 in WC)
- Low profile
- Lowest life cycle costs for high ventilation rates (> 50,000 cfm)

#### Disadvantages

- Low to high capital cost depending on system sophistication
- Media replacement (3-5 years for organic media)
- High water consumption (humidification)
- Poor response to changes in pollutant loading
- Large footprint
- Background odor of media
- Short circuiting for traditional open bed filters

## **Opinion of Probable Project Costs**

#### **Assumptions**

Cost for 25% Sodium Hydroxide 0.95 \$/gal Cost for 12.5% Hypochlorite 0.91 \$/gal Cost for 93% Sulfuric Acid 3.53 \$/gal

Cost for Water (Reclaimed) 0.00 \$/gal Cost for Electricity 0.0602 \$/kWh

Consumables Manufacturer's Input

Technician labor rate 50 \$/hr
Life Cycle 20 years
Interest rate 5.0% per year
Contingency 15%

## **Summary of Alternatives for the Dewatering Facility**

Alternative No. D1 - Chemical Scrubber

Alternative No. D2 - Photoionization

Alternative No. D3 - Carbon Adsorber

Alternative No. D4 - Bio-Trickling Filter

Alternative No. D5 - Liquid Sludge Treatment


Alternative No. D6 - Ionization

## Dewatering: Alternative No. D1 - Chemical Scrubber

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 486,000 Engineering/Administrative: \$ 97,320 Contingency: \$ 87,590 Project Capital Cost: \$ 671,508 Annual Operating Cost: \$ 130,510 Annual Debt Service: \$ 53,884

Present Value: \$2,297,945




## Dewatering: Alternative No. D2 - Photoionization

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 881,600
Engineering/Administrative: \$ 88,160
Contingency: \$ 145,500
Project Capital Cost: \$1,115,224
Annual Operating Cost: \$ 101,641
Annual Debt Service: \$ 89,488

Present Value: \$2,381,897




## Dewatering: Alternative No. D3 - Carbon Adsorber

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 659,500 Engineering/Administrative: \$ 79,140 Contingency: \$ 110,800 Project Capital Cost: \$ 849,436 Annual Operating Cost: \$ 65,139 Annual Debt Service: \$ 68,161

Present Value: \$1,661,206




## Dewatering: Alternative No. D4 - Bio-Trickling Filter

#### **Opinion of Costs Summary**

Construction Capital Cost: \$1,264,499
Engineering/Administrative: \$ 126,450
Contingency: \$ 208,642
Project Capital Cost: \$ 1,599,591
Annual Operating Cost: \$ 43,501
Annual Debt Service: \$ 128,355

Present Value: \$2,141,707



## Dewatering: Alternative No. D5 - Liquid Sludge Treatment

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 30,700 Engineering/Administrative: \$ 20,000 Contingency: \$ 7,605 Project Capital Cost: \$ 58,305 Annual Operating Cost: \$ 93,757 Annual Debt Service: \$ 4,679

Present Value: \$1,226,721





## Dewatering: Alternative No. D6 - Ionization

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 697,600 Engineering/Administrative: \$ 104,640 Contingency: \$ 120,340 Project Capital Cost: \$ 922,576 Annual Operating Cost: \$ 33,747 Annual Debt Service: \$ 74,030

Present Value: \$1,343,139





#### Summary of Alternatives for the Composting Facility

#### Alternative No. C1A - Existing Biofilter Support Gravel and Media Replacement

Remove and replace gravel and biofilter media

#### Alternative No. C1B - Replace Existing Biofilter Media and Improve Flushing Access

- Remove and replace gravel and biofilter media
- Modify air distribution piping at end to facilitate cleaning

#### Alternative No. C1C – Existing Biofilter Upgrade

- Add humidifiers
- Replace air distribution piping with slotted open floor
- Replace media with root compost

#### Alternative No. C2 - Concrete Biofilter with Engineered Media

■ Install a new Concrete Biofilter System with Engineered Media

#### Alternative No. C3 - Chemical Scrubber System

• Install five (5) two-stage chemical scrubbers with chemical storage building

#### Alternative No. C4 - Ionization


Ionization Generators

# Composting: Alternative No. C1A - Replace Existing Biofilter Media

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 432,876 Engineering/Administrative: \$ 43,290 Contingency: \$ 71,425 Project Capital Cost: \$ 547,588 Annual Operating Cost: \$ 187,072 Annual Debt Service: \$ 43,940

Present Value: \$2,878,919




# Composting: Alternative No. C1B - Replace Existing Biofilter Media and Improve Flushing Access

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 736,551
Engineering/Administrative: \$ 73,655
Contingency: \$ 121,531
Project Capital Cost: \$ 931,737
Annual Operating Cost: \$ 187,072
Annual Debt Service: \$ 74,765

Present Value: \$3,263,068




# Composting: Alternative No. C1C - Existing Biofilter Upgrade

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 2,254,328
Engineering/Administrative: \$ 225,433
Contingency: \$ 371,964
Project Capital Cost: \$ 2,851,725
Annual Operating Cost: \$ 164,244
Annual Debt Service: \$ 228,830
Present Value: \$ 4,898,572


- 1. Coarse shredded, composted, tree root media
- 2. Water scrubber (humidifier) on each fan
- 3. Add Variable Frequency Drives
- 4. Secondary humidification system (grid of soaker hoses)



# Composting: Alternative No. C2 - Concrete Biofilter with Engineered Media

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 5,284,910
Engineering/Administrative: \$ 528,500
Contingency: \$ 872,010
Project Capital Cost: \$ 6,685,411
Annual Operating Cost: \$ 141,141
Annual Debt Service: \$ 536,455
Present Value: \$ 8,444,342




# Composting: Alternative No. C3 – Chemical Scrubber System

#### **Opinion of Costs Summary**

Construction Capital Cost: \$ 2,298,010
Engineering/Administrative: \$ 344,702
Contingency: \$ 396,410
Project Capital Cost: \$ 3,039,118
Annual Operating Cost: \$ 2,310,421
Annual Debt Service: \$ 243,867

Present Value: \$31,8



## Composting: Alternative No. C4 - Ionization


#### **Opinion of Costs Summary**


Construction Capital Cost: \$ 2,429,300 Engineering/Administrative: \$ 364,395 Contingency: \$ 419,055 Project Capital Cost: \$ 3,212,749 Annual Operating Cost: \$ 94,894

Annual Debt Service: \$ 94,894


Annual Debt Service: \$ 257,799

Present Value: \$ 4,395,340





## Dewatering and Composting: Alternative No. DC1 -Concrete Biofilter with Engineered Media **Opinion of Costs Summary Construction Capital Cost:** \$ 6,350,180 Engineering/Administrative: \$ 635,018 Contingency: \$ 1,047,780 Project Capital Cost: \$ 8,032,978 \$ 173,223 Annual Operating Cost: Annual Debt Service: \$ 644,587 **Present Value:** \$10,191,724



Criteria	D1 Chemical Scrubber	D2 Photo-ionization	D3 Carbon Adsorber	D4 Bio-Trickling Filter	D5 Liquid Sludge Treatment	D6 Ionization
lumber of Units	1	3	2	3	1	3
Jnit Dimensions L x W x H) or diameter x H	17.5 ft x 9.5 ft x 13.0 ft	14.4 ft x 7.2 ft x 10.5 ft	11 ft diameter x 16.75 ft (19.5 ft x 12 ft x 16.75 ft)	12.0 ft diameter x 32.0 ft (19.5 ft x 12 ft x 32.0 ft)	Not Applicable	(1) @ 21.3 ft x 6.7 ft (2) @ 6.0 ft x 3.5 ft
verall Foot Print (ft²)	238	311	468	702	100	185
mproves Indoor Odors	No	No	No	No	Yes	Yes
educes Indoor Particulates	No	No	No	No	No	Yes
dor Reduction	95%	>95%	95%, limited with ammonia and amines	90-95%	Difficult to predict, specific to H <sub>2</sub> S and organic sulfur compounds	90% reduction of H <sub>2</sub> S ar NH <sub>3</sub> , less for other odorants
onfined Space Entry	When entering vessel, which may be required to clean media.	No	When entering vessel, which may be required during media replacement	When entering vessel, which may be required during media cleaning and replacement.	No	No
ndustry Experience	Well established	Well established in Europe. Limited installations in the US, but notable installations in North America.	Well established	Well established	Well established	Moderately established
∕ledia Handling	Periodic cleaning (if required based on air quality and water quality), media life expected to be 20 years	Not applicable	Carbon must be replaced when breakthrough occurs, requiring disposal of old media (6 months to 5 years depending on odorant concentrations)	Periodic cleaning if required. Replacement at 10 year intervals.	Not applicable	Not applicable
onsumables	Chemicals as required, Media at 20 years and Chemical meter pumps at 5 years.	UV Lamps and Catalyst with replacement every 14-18 months	Carbon media with replacement every five years.	Nutrients as required and media at 10 years.	Chemicals, Metering pumps at five years.	Air filters and ionization tubes at 18 months
nnual Maintenance Hours	260	130	416	156	260	164
innual Water Usage gallons)	131,626 minimum based on projected H <sub>2</sub> S concentration, but could be 1,576,800 at typical replenishment rates	None	None	247,000 minimum based on projected H <sub>2</sub> S concentrations, but could be 2,960,000 at typical design rates.	None	None
hemicals	NaOH, NaOCI, H <sub>2</sub> SO <sub>4</sub>	None	None	Nutrients	Oxidants	None
otential for Operational Ipset	Medium (chemical adjustment)	Low	Low	High (biological process, temperature and pH ranges)	Medium (chemical adjustment)	Low
8.M Cost Stability with arying Odorant concentrations	Low – higher odorant loadings can increase chemical usage and O&M costs.	High – handles odorant concentration variability well without notable increases in O&M	Low – increased odorant concentrations can cause more frequent media replacement, increasing O&M costs.	High – subtle increases in odorant levels can be handled without increased O&M.	Low – higher sulfides in the liquid sludge and lower oxygen levels can require more chemical, resulting in higher O&M costs.	High - handles odorant concentration variability well without notable increases in O&M
resent Value Rank 1 lowest to 6 highest)	5 (\$2,300,797)	6 (\$2,465,664)	3 (\$1,662,683)	4 (\$2,143,047)	1 (\$1,226,738)	2 (\$1,344,060)

Criteria	C1A Replace Biofilter Media	C1B Replace Biofilter Media and Improve Flushing Access	C1C Existing Biofilter Upgrade	C2 Concrete Biofilter with Engineered Media	C3 Chemical Scrubber System	C4 Ionization
Number of Units/Cells	1	1	1	4	5	6
Jnit Dimensions L x W x H)	Not applicable	Not applicable	Not applicable	80 ft x 50 ft	17.5 ft x 9.5 ft x 13.0 ft	(2) @ 7.5 ft x 6.8 ft x 5.3 ft (2) @ 11.5 ft x 6.8 ft x 5.3 ft (2) @ 6 ft x 6.8 ft x 5.3 ft
Overall Foot Print (ft²)	26,215	26,215	26,215	16,000	1,935 (including chemical building)	340 for IM and 600 for wet scrubbers (total = 940)
mproves Indoor Odors	No	No	No	No	No	Yes
Reduces Indoor Particulates	No	No	No	No	No	Yes
Odor Reduction	90-95%	90-95%	90-95%	90-95%	95%	<90%, 90% reduction of H <sub>2</sub> S and NH <sub>3</sub> , less for other odorants
Confined Space Entry	Yes (every one or two months for lateral flushing and nozzle exchange)	Yes (two to three months for nozzle exchange)	Yes, but only when evaluating dust build-up in open floor system	Yes, but only when cleaning top of filter	Yes, when entering vessel, which may be required to clean media.	No
ndustry Experience	Well established	Well established	Well established	Well established	Well established	Moderately established
Air Distribution	Perforated lateral	Perforated lateral	Open floor	Open (down forced)	Not Applicable	Perforated lateral inside building
Media	Organic – wood chip and leaf compost	Organic – wood chip and leaf compost	Organic – composted tree roots	Mineral based	Synthetic	Not applicable
Media Replacement (years)	3-5	3-5	3-5	20	20	Not applicable
Consumables	Media	Media	Media	Media	Chemicals, Metering pumps at five years.	Air filters and ionization tubes at 18 months
Annual Maintenance Hours	514	514	130	130	260	164
Annual Water Usage (gallons)	3,153,600	3,153,600	3,153,600	2,241,100	718,000	None
themicals	None	None	None	None	NaOH, NaOCI, H <sub>2</sub> SO <sub>4</sub>	None
otential for Operational	High – biological process subject to variable environmental conditions.	High – biological process subject to variable environmental conditions.	High – biological process subject to variable environmental conditions.	Low-Medium	Medium (chemical adjustment)	Low
&M Cost Stability with arying Odorant concentrations	High	High	High	High	Low – higher odorant loadings can increase chemical usage and O&M costs.	High
resent Value Rank 1 lowest to 6 highest)	1 (\$2,888,194)	2 (\$3,362,000)	4 (\$4,904,275)	5 (\$8,450,044)	6 (\$13,348,373)	3 (\$4,399,173)

